

October 24, 2016

Mike Burke
Farmer Environmental Service
108 Emerald Hills Dr.
Edwardsville, IL 62025
TEL: (618) 656-6988
FAX: (618) 656-8353



RE: Northwestern CUSD #2 Elementary 1609-540

WorkOrder: 16091763

Dear Mike Burke:

TEKLAB, INC received 16 samples on 9/27/2016 9:56:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	4
Laboratory Results	5
Receiving Check List	21
Chain of Custody	Appended

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

Abbr Definition

- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilutions factors.
- DNI Did not ignite
- DUP Laboratory duplicate is an aliquot of a sample taken from the same container under laboratory conditions for independent processing and analysis independently of the original aliquot.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample, spiked with verified known amounts of analytes, is analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system. The acceptable recovery range is in the QC Package (provided upon request).
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL Method detection limit means the minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is greater than zero.
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
- PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions. The acceptable recovery range is listed in the QC Package (provided upon request).
- RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
- RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
- SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
- Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
- TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)

Qualifiers

- | | |
|--|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| E - Value above quantitation range | H - Holding times exceeded |
| I - Associated internal standard was outside method criteria | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

Cooler Receipt Temp: 18.82 °C

Locations and Accreditations

	<u>Collinsville</u>	<u>Springfield</u>	<u>Kansas City</u>	<u>Collinsville Air</u>
Address	5445 Horseshoe Lake Road Collinsville, IL 62234-7425	3920 Pintail Dr Springfield, IL 62711-9415	8421 Nieman Road Lenexa, KS 66214	5445 Horseshoe Lake Road Collinsville, IL 62234-7425
Phone	(618) 344-1004	(217) 698-1004	(913) 541-1998	(618) 344-1004
Fax	(618) 344-1005	(217) 698-1005	(913) 541-1998	(618) 344-1005
Email	jhriley@teklabinc.com	KKlostermann@teklabinc.com	Ryoungstrom@teklabinc.com	EHurley@teklabinc.com

<u>State</u>	<u>Dept</u>	<u>Cert #</u>	<u>NELAP</u>	<u>Exp Date</u>	<u>Lab</u>
Illinois	IEPA	100226	NELAP	1/31/2017	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2017	Collinsville
Louisiana	LDEQ	166493	NELAP	6/30/2017	Collinsville
Louisiana	LDEQ	166578	NELAP	6/30/2017	Collinsville
Texas	TCEQ	T104704515-12-1	NELAP	7/31/2017	Collinsville
Arkansas	ADEQ	88-0966		3/14/2017	Collinsville
Illinois	IDPH	17584		5/31/2017	Collinsville
Kentucky	KDEP	98006		12/31/2016	Collinsville
Kentucky	UST	0073		1/31/2017	Collinsville
Missouri	MDNR	00930		5/31/2017	Collinsville
Missouri	MDNR	930		1/31/2017	Collinsville
Oklahoma	ODEQ	9978		8/31/2017	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-001
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #1 Kitchen 3 Bowel Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0057	mg/L	5	10/23/2016 16:41	123094



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-002
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #2 Kitchen Hand Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0017	mg/L	5	10/23/2016 17:10	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-003
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #3 Fountain Multi Purpose/Cafeteria
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0016	mg/L	5	10/23/2016 17:15	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

Lab ID: 16091763-004

Client Sample ID: #4 Fountain by Bath Rooms

Matrix: DRINKING WATER

Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 17:21	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-005
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #5 Fountain by Rm 138
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 17:26	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-006
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #6 Fountain by Rm 121
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0014	mg/L	5	10/23/2016 17:32	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-007
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #7 Teachers Lounge Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0022	mg/L	5	10/23/2016 17:38	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-008
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #8 Kitchen 3 Bowel Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 17:55	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

Lab ID: 16091763-009

Client Sample ID: #9 Kitchen Hand Sink

Matrix: DRINKING WATER

Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 18:00	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-010
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #10 Fountain at Cafeteria
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0013	mg/L	5	10/23/2016 18:17	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-011
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #11 Fountain in Hallway by 148
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 18:23	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-012
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #12 Fountain Hallway by 142
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 18:29	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-013
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #13 Teachers Lounge Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 18:34	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-014
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #14 Home Eck by Outside Wall Sink
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	10/23/2016 18:40	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-015
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #15 Fountain Hallway by Rm 106
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0011	mg/L	5	10/23/2016 18:45	123096



Laboratory Results

<http://www.teklabinc.com/>

Client: Farmer Environmental Service
Client Project: Northwestern CUSD #2 Elementary 1609-540
Lab ID: 16091763-016
Matrix: DRINKING WATER

Work Order: 16091763
Report Date: 24-Oct-16
Client Sample ID: #16 Fountain Hallway by Library
Collection Date: 09/27/2016 6:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0023	mg/L	5	10/23/2016 18:51	123096



Receiving Check List

<http://www.teklabinc.com/>

Client: Farmer Environmental Service

Work Order: 16091763

Client Project: Northwestern CUSD #2 Elementary 1609-540

Report Date: 24-Oct-16

Carrier: Mark Ramsey

Received By: MLA

Completed by:

Amber Dilallo

Reviewed by:

Elizabeth A. Hurley

On:

27-Sep-16

Amber M. Dilallo

On:

27-Sep-16

Elizabeth A. Hurley

Pages to follow: Chain of custody

Extra pages included

- Shipping container/cooler in good condition? Yes No Not Present Temp °C **18.82**
- Type of thermal preservation? None Ice Blue Ice Dry Ice
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Reported field parameters measured: Field Lab NA
- Container/Temp Blank temperature in compliance? Yes No

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- Water – at least one vial per sample has zero headspace? Yes No No VOA vials
- Water - TOX containers have zero headspace? Yes No No TOX containers
- Water - pH acceptable upon receipt? Yes No NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes No NA

Any No responses must be detailed below or on the COC.

#6 Fountain by Rm 121 is labeled as by Rm 127. Per Mik Burke, report the room number as 121. AMD 9/27/16

Samples were preserved with nitric acid upon arrival at the laboratory. AMD 9/27/16

CHAIN OF CUSTODY

pg. 1 of 2 Work order # 16091763

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Farmer Environmental Service
Address: 108 Emerald Hills Dr.
City / State / Zip: Edwardsville, IL 62025
Contact: Mike Burke **Phone:** (618) 656-6988
E-Mail: mike@farmerenv.com **Fax:** (618) 656-8353

Samples on: ICE BLUE ICE NO ICE 18.82 °C
Preserved in: LAB FIELD **FOR LAB USE ONLY**
Lab Notes: HNO3 9/27/16

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. Yes No

Project Name/Number		Sample Collector's Name		MATRIX								INDICATE ANALYSIS REQUESTED											
Northwestern CUSD #2 <u>Elementary 1609-548</u>		<u>Mark Ramsey</u>		Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead													
Results Requested		Billing Instructions									# and Type of Containers												
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER												
Lab Use Only	Sample Identification	Date/Time Sampled																					
<u>16091763-001</u>	<u>#1 Kitchen</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>												
<u>002</u>	<u>3 Bowl sink</u>																						
<u>002</u>	<u>#2 Kitchen</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>												
	<u>Hand sink</u>																						
<u>003</u>	<u>#3 Fountain</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>												
	<u>multi purpose/cofactor</u>																						
<u>004</u>	<u>#4 Fountain BY</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>												
	<u>Bath Rooms</u>																						
<u>005</u>	<u>#5 Fountain BY</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>												
	<u>Rm 138</u>																						

Relinquished By	Date/Time	Received By	Date/Time
<u>Mark Ramsey</u>	<u>9/27/16 9:56</u>	<u>Muller</u>	<u>9/27/16 9:56</u>

CHAIN OF CUSTODY

pg. 4 of 4 Work order # 16091763

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Farmer Environmental Service
Address: 108 Emerald Hills Dr.
City / State / Zip: Edwardsville, IL 62025
Contact: Mike Burke **Phone:** (618) 656-6988
E-Mail: mike@farmerenv.com **Fax:** (618) 656-8353

Samples on: ICE BLUE ICE NO ICE 16.82 °C
Preserved in: LAB FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. Yes No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																		
Northwestern CUSD #2 <u>Jr./Sr. High 1609-543</u>		<u>Mark Ramsey</u>		Drinking Water	Soil	Sludge	Groundwater	Lead																
Results Requested	Billing Instructions	# and Type of Containers																						
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER															
Lab Use Only	Sample Identification	Date/Time Sampled							Aqueous															
	<u>#13 Teachers Lounge sink</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>															
	<u>#14 Home Eck BY OUTSIDE WALL SINK</u>	<u>9/27/16 6:30</u>	<input type="checkbox"/>						<input type="checkbox"/>															
	<u>#15 Fountain Hallway BY Rm 106</u>	<u>9/27/16 6:30</u>	<input type="checkbox"/>						<input type="checkbox"/>															
	<u>#16 Fountain Hallway BY LIBRARY</u>	<u>9/27/16 6:30</u>	<input checked="" type="checkbox"/>						<input checked="" type="checkbox"/>															

16091763-

Relinquished By	Date/Time	Received By	Date/Time
<u>Mark Ramsey</u>	<u>9/27/16 9:56</u>	<u>Mark Ramsey</u>	<u>9/27/16 9:56</u>